



## Approval of the Trademark Trevira CS®

AB Ludvig Svensson  
Bangatan 8  
51182 Kinna  
Sweden

<b>Application No.:</b>	220109
<b>Date of issue:</b>	11.03.2022
<b>Valid until:</b>	11.03.2027
<b>Article name:</b>	Basal
<b>End use:</b>	Curtains
<b>Square weight (g/m<sup>2</sup>):</b>	230
<b>According to customer specification</b>	
<b>Composition of the raw materials:</b>	Polyester 100%
<b>Composition of the fabric:</b>	Trevira CS 100%
<b>Yarn:</b>	Warp, 167 f 64 x 1 dtex Trevira® Type 594E, Yarn supplier Trevira Weft, 60 / 2 Nm Trevira® Type T270, Yarn supplier Fil Man Made

The tested article Basal with application no. 220109 is granted approval for the trademark Trevira CS® for interior use.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Trevira GmbH  
(This document is valid without signature.)