

## Reaction to fire classification according to EN 45545-2

(1 appendix)

### Introduction

This classification report defines the reaction to fire classification assigned to the product called “Incendo” in accordance with EN 45545-2:2013+A1:2015.

Test reports and test results in support of classification, together with the classification criteria, are presented in appendix 1.

### Product description

According to the client: Roller blind called “Incendo”, consisting of 100 % Trevira CS. The product has a nominal thickness of  $0.5 \pm 0.1$  mm, a nominal area weight of  $170 \text{ g/m}^2$  and the colour is grey (8400). Detailed product description is filed at RISE.

According to the standard EN 45545-2, table 2, the product is defined as a “Listed Product” to which the following parameters apply:

Product No:	IN8
Location:	Interior
Description:	Interiors
Product name:	Curtains and sunblind in passenger and staff area, staff compartments
Requirement Set:	R1

### Classification

The product described above, in relation to its reaction to fire behaviour, is classified according to EN 45545-2:2013+A1:2015, Requirement Set R1; Hazard Levels HL1 and HL2.

**Reaction to fire classification: *R1; HL1/HL2***

### Field of application

This classification is valid for the following product parameters:

Nominal thickness:  $0.5 \pm 0.1$  mm.

Nominal area weight:  $170 \text{ g/m}^2$ .

### RISE Research Institutes of Sweden AB

Postal address	Office location	Phone / Fax / E-mail
Box 857 SE-501 15 BORÅS Sweden	Brinellgatan 4 SE-504 62 BORÅS	+46 10 516 50 00 +46 33 13 55 02 info@ri.se

This document may not be reproduced other than in full, except with the prior written approval of RISE.

**Limitations**

This classification document does not represent type approval or certification of the product.

The sample was delivered by the client. RISE Safety – Fire Research was not involved in the sampling procedure.

**RISE Research Institutes of Sweden AB  
Safety - Fire Research Dynamics**

Performed by

Examined by

Anna Bergstrand

Per Thureson

**Appendix**

## 1. Basis for fire classification



Appendix 1

**Basis for fire classification**

**1 Test reports & test results in support of classification**

**1.1 Test reports**

This classification, according to EN 45545-2, is based on the test reports:

Laboratory	Sponsor	Test report no	Accredited test method
RISE	AB Ludvig Svensson	8P01249	ISO 5658-2
RISE	AB Ludvig Svensson	8P01249-1	ISO 5660-1
RISE	AB Ludvig Svensson	8P01249-2	EN ISO 5659-2+ EN 45545-2, annex C

**1.2 Test results**

Mean values of the test results are summarized:

Test method	Number of tests	Parameter	Results, mean value	Compliance with Requirement Set; Hazard Level
<i>ISO 5658-2</i> <i>(ref. 8P01249)</i>	4			
Critical Flux at Extinguishment		CFE	47 kW/m <sup>2</sup>	R1; HL1/HL2/HL3
<i>ISO 5660-1: 50 kW/m<sup>2</sup></i> <i>(ref. 8P01249-1)</i>	3			
Maximum Average Rate of Heat Emission		MARHE	63 kW/m <sup>2</sup>	R1; HL1/HL2
<i>ISO 5659-2: 50 kW/m<sup>2</sup> without pilot burner</i> <i>(ref. 8P01249-2)</i>	3			
Maximum specific optical density of smoke at 4 min, D <sub>s</sub> (4)		D <sub>s</sub> (4)	99	R1; HL1/HL2/HL3
Cumulative value of specific optical density of smoke in the first 4 minutes		VOF <sub>4</sub>	218	R1; HL1/HL2/HL3
Conventional index of toxicity, General products		CIT <sub>G</sub>	0.01	R1; HL1/HL2/HL3

**2 Reaction to Fire Classification**

**2.1 Reference for classification**

According to EN 45545-2 “Railway applications – Fire protection on railway vehicles – Part 2: Requirements for fire behaviour of materials and components”, to meet the set of material requirements according to table 5, requirement set R1, the product must fulfil the classification criteria for each test method tested as described below.

Appendix 1

**2.2 Classification criteria**

Classification criteria according to Requirement Set R1 are summarized as follows:

<i>Test method</i>	HL1	HL2	HL3
<i>ISO 5658-2</i>			
Critical Flux at Extinguishment, CFE (kW/m <sup>2</sup> )	≥ 20	≥ 20	≥ 20
<i>ISO 5660-1: 50 kW/m<sup>2</sup></i>			
Maximum Average Rate of Heat Emission, MARHE (kW/m <sup>2</sup> )	-	≤ 90	≤ 60
<i>ISO 5659-2: 50 kW/m<sup>2</sup>, without pilot flame</i>			
Maximum specific optical density of smoke at 4 min, D <sub>s</sub> (4)	≤ 600	≤ 300	≤ 150
Cumulative value of specific optical density of smoke in the first 4 minutes, VOF <sub>4</sub>	≤ 1200	≤ 600	≤ 300
Conventional index of toxicity, General products, CIT <sub>G</sub>	≤ 1.2	≤ 0.9	≤ 0.75