

**Application for approval of the trademark  
TREVIRA®**Applicant

Company	AB Ludvig Svensson
Road	Bangatan 8
Post Code/City	511 82 Kinna
Country	Sweden

Trevira GmbH  
 Markenprüfung /  
 Trademark Testing  
 Technikum, Gebäude 515  
 Max-Fischer-Straße 11  
 D-86399 Bobingen

Name / Signature	2018-03-15
------------------	------------

Trademark	Trevira CS
-----------	------------

Article	Well
---------	------

End Use	Drapes
---------	--------

Other uses	EN 13773, Class 1; SN 198898; UNI 8456/8457; NF P 92-503-507, M1
------------	--

Composition	100% Trevira CS
-------------	-----------------

Fabric weight (g/sm)	290
----------------------	-----

Yarn Details**Warp**

Yarn titre/ count	Nm 40/2
-------------------	---------

Trevira Type	270
--------------	-----

Yarn supplier	Fil Man Made
---------------	--------------

**Weft 1****Weft 2****Weft 3**

Yarn titre/ count	Nm 20/2	Nm 40/2	--
-------------------	---------	---------	----

Trevira Type	270	270	--
--------------	-----	-----	----

Yarn supplier	Lampertsmuhle / Fil Man Made		
---------------	------------------------------	--	--

**Approval: 17.05.2018**

(This Trademark approval is valid for a period of 5 years from the date of issue).

The tested article WELL with application no. 180519 is granted approval for the trademark Trevira CS for interior use. This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

This article can also meet the requirements for the fire index BKZ 5.3 (BKZ = fire index, combustibility 5 = flame retardant, level of smoke emission 3 = low smoke emission) according to the Swiss standard SN 198898.

17.05.2018 i.A. Empack

Trevira GmbH, Trademark Service