



## Approval of the Trademark Trevira CS®

AB Ludvig Svensson  
 Bangatan 8  
 51182 Kinna  
 Sweden

**Application No.:** 240323  
**Date of issue:** 03.06.2024  
**Valid until:** 03.06.2029

**Article name:** Calla  
**End use:** Curtains  
**Square weight (g/m<sup>2</sup>):** 360  
 According to customer specification  
**Composition of the raw materials:** Polyester 100%  
**Composition of the fabric:** Trevira CS 100%

**Yarn:** Warp, 167 f 64 x 1 dtex Trevira® Type 532E,  
 Yarn supplier Trevira  
 Warp, 500 f 192 x 1 dtex Trevira® Type 593M,  
 Yarn supplier Trevira  
 Warp, 85 / 2 Nm Trevira® Type T270,  
 Yarn supplier Trevira  
 Weft, 40 / 2 Nm Trevira® Type T270,  
 Yarn supplier Trevira  
 Weft, 500 f 192 x 1 dtex Trevira® Type 593M,  
 Yarn supplier Trevira

The tested article Calla with application no. 240323 is granted approval for the trademark Trevira CS® for interior use.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 10 January 2024.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

This article can also meet the requirements for the fire index BKZ 5.3 (BKZ = fire index, combustibility 5 = flame retardant, level of smoke emission 3 = low smoke emission) according to the Swiss standard SN 198898.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Indorama Ventures Fibers Germany GmbH  
 (This document is valid without signature.)