



## Approval of the Trademark Trevira CS®

Ara

90

Curtains

Polyester 100%

Trevira CS 100%

AB Ludvig Svensson Bangatan 8 51182 Kinna Sweden

 Application No.:
 240322

 Date of issue:
 05.06.2024

 Valid until:
 05.06.2029

Article name: End use: Square weight (g/m<sup>2</sup>): According to customer specification Composition of the raw materials: Composition of the fabric:

sition of

Yarn:

Warp, 85 / 2 Nm Trevira® Type T270, Yarn supplier Fil Man Made Weft, 85 / 2 Nm Trevira® Type T270, Yarn supplier Fil Man Made

The tested article Ara col. blue/green with application no. 240322 is granted approval for the trademark Trevira CS® for interior use.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article meets the requirements for class 1 according to EN 13773.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 10 January 2024.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457. This article can also meet the requirements for the fire index BKZ 5.3 (BKZ = fire index, combustibility 5 = flame retardant, level of smoke emission 3 = low smoke emission) according to the Swiss standard SN 198898.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Indorama Ventures Fibers Germany GmbH (This document is valid without signature.)

Indorama Ventures Fibers Germany GmbH, Trademark Service, Max-Fischer-Straße 11, 86399 Bobingen, Germany E-Mail: <u>trademarkservice.IVFG@de.indorama.net</u>