



Approval of the Trademark Trevira CS®

AB Ludvig Svensson Bangatan 8 51182 Kinna Sweden

 Application No.:
 220293

 Date of issue:
 28.04.2022

 Valid until:
 28.04.2027

Article name: Prime
End use: Curtains
Square weight (g/m²): 360

According to customer specification

Composition of the raw materials: Polyester 100%
Composition of the fabric: Trevira CS 100%

Yarn: Warp, 10 / 2 Nm Trevira® Type T270,

Yarn supplier VLNAP

Weft, 10 / 2 Nm Trevira® Type T270,

Yarn supplier VLNAP

The tested article Prime with application no. 220293 is granted approval for the trademark Trevira CS® for interior use.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507. The article meets the requirements for class 1 according to EN 13773.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C. Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457. This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Trevira GmbH

(This document is valid without signature.)