



Approval of the Trademark Trevira CS®

AB Ludvig Svensson
Bangatan 8
51182 Kinna
Sweden

Application No.: 181569
Date of issue: 28.12.2018
Valid until: 28.12.2023

Article name: WOOD
End use: Drapes

Square weight (g/m²): 90

According to customer specification

Composition of fabric: Polyester 100% Trevira CS
Yarn: Warp: 84 / 2 Nm Trevira® Type 270, Yarn supplier Fil Man Made
Weft: 84 / 2 Nm Trevira® Type 270, Yarn supplier Fil Man Made

The tested article WOOD with application no. 181569 is granted approval for the trademark Trevira CS® for interior use. This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

Thus meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457.

The article was tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

This article can also meet the requirements for the fire index BKZ 5.3 (BKZ = fire index, combustibility 5 = flame retardant, level of smoke emission 3 = low smoke emission) according to the Swiss standard SN 198898.

Trevira GmbH
(This document is valid without signature.)

Trevira GmbH, Trademark Service, Max-Fischer-Straße 11, 86399 Bobingen, Germany
E-Mail: trademark.service@trevira.com