



Approval of the Trademark Trevira CS®

AB Ludvig Svensson
Bangatan 8
51182 Kinna
Sweden

Application No.: 210194
Date of issue: 15.04.2021
Valid until: 15.04.2026

Article name: Sumire
End use: Curtains
Square weight (g/m²): 150
According to customer specification
Composition of the raw materials: Polyester 100%
Composition of the fabric: Trevira CS 100%

Yarn: Warp, 60 / 2 Nm Trevira® Type 270,
Yarn supplier Fil Man made
Weft, 60 / 2 Nm Trevira® Type 270,
Yarn supplier Fil man made

The tested article Sumire with application no. 210194 is granted approval for the trademark Trevira CS® for interior use. This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.
The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.
The article was tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.
This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.
Thus meets also the requirements according to British Standard BS 5867 part 2 type C.
Thus meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457.
This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Trevira GmbH
(This document is valid without signature.)