



Approval of the Trademark Trevira CS®

AB Ludvig Svensson
 Bangatan 8
 51182 Kinna
 Sweden

Application No.: 230313
Date of issue: 26.05.2023
Valid until: 26.05.2028

Article name: Nova
End use: Curtains
Square weight (g/m²): 110
 According to customer specification
Composition of the raw materials: Polyester 100%
Composition of the fabric: Trevira CS 100%

Yarn: Warp, 85 / 2 Nm Trevira® Type T270,
 Yarn supplier Filmanmade
 Weft, 40 / 2 Nm Trevira® Type T270,
 Yarn supplier Selvafil

The tested article Nova with application no. 230313 is granted approval for the trademark Trevira CS® for interior use.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1.

Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.

This article can also meet the requirements for the fire index BKZ 5.3 (BKZ = fire index, combustibility 5 = flame retardant, level of smoke emission 3 = low smoke emission) according to the Swiss standard SN 198898.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Indorama Ventures Fibers Germany GmbH
 (This document is valid without signature.)