



Approval of the Trademark Trevira CS®

AB Ludvig Svensson
Bangatan 8
51182 Kinna
Sweden

Application No.:	200364
Date of issue:	15.06.2020
Valid until:	15.06.2025
Article name:	Mineral
End use:	Interior Solar Shading
Square weight (g/m²):	170
According to customer specification	
Composition of the raw materials:	Polyester 100%
Composition of the fabric:	Trevira CS 100%

Yarn: Knitted fabric, 167 f 64 x 1 dtex Trevira® Type 593W,
Yarn supplier Trevira
Knitted fabric, 76 f 24 x 1 dtex Trevira® Type 691M,
Yarn supplier Trevira

The tested article Mineral with application no. 200364 is granted approval for the trademark Trevira CS® for interior use. This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article was tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

Thus meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Trevira GmbH
(This document is valid without signature.)

Trevira GmbH, Trademark Service, Max-Fischer-Straße 11, 86399 Bobingen, Germany
E-Mail: trademark.service@trevira.com