



## Approval of the Trademark Trevira CS®

AB Ludvig Svensson  
Bangatan 8  
51182 Kinna  
Sweden

**Application No.:** 200229  
**Date of issue:** 24.03.2020  
**Valid until:** 24.03.2025

**Article name:** Felix  
**End use:** Curtains  
**Square weight (g/m<sup>2</sup>):** 110  
**According to customer specification**  
**Composition of the raw materials:** Polyester 100%  
**Composition of the fabric:** Trevira CS 100%

**Yarn:** Warp, 84 / 2 Nm Trevira® Type 270,  
Yarn supplier Fil Man Made  
Weft, 40 / 2 Nm Trevira® Type 270,  
Yarn supplier Fil Man Made

The tested article Felix with application no. 200229 is granted approval for the trademark Trevira CS® for interior use. This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1. The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507. The article was tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773. Thus meets also the requirements according to British Standard BS 5867 part 2 type C. Thus meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457. This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781). This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.

Trevira GmbH  
(This document is valid without signature.)

Trevira GmbH, Trademark Service, Max-Fischer-Straße 11, 86399 Bobingen, Germany  
E-Mail: [trademark.service@trevira.com](mailto:trademark.service@trevira.com)